



Mr Con Morris
Product Manager
Dustex Australia Pty Ltd
End of Anderson Road
Henderson WA 6166

Dear Mr Morris

DUSTEX FL 875L - APPROVAL

Thank you for your enquiry seeking approval for the use of the above dust suppressant product within drinking water catchments in Western Australia. We have noted your advice that Dustex FL 875L is a lignosulphonate-based stabiliser incorporated during the watering process using conventional roadmaking equipment or a high-capacity road stabiliser.


The product is approved for use within drinking water catchments in Western Australia subject to the following conditions:

- Use must be in accordance with the manufacturer's instructions with due regard to occupational safety for users or operators and any Dangerous Goods requirements;
- Use must not exceed an application volume of 0.8 litres per square metre in any single dose and must not exceed a total 12 month accumulated application volume of more than 1.8 litres per square metre;
- Use is only permitted for surfaces that are not subjected to continual immersion.

The product will be listed under Schedule 9 of the Department's "*Materials, products and substances in contact with drinking water*" fact sheet¹. The supplied chemical disclosure and product bulletins will be held in confidence. Please note that use of this product for surfaces that are subject to continual immersion within drinking water catchments in Western Australia requires separate approval.

Please note that this does not constitute an endorsement of the product by the Department of Health WA and should not be advertised as such. If you require any additional information, please contact Mr Brian Labza of this office on (08) 9222 0241.

Yours sincerely


Richard Theobald
Managing Scientist
Water

8 April 2026

¹<https://ww2.health.wa.gov.au/~media/Files/Corporate/general%20documents/water/PDF/MaterialsSubstancesDrinkingWater.pdf>